



**Dream Pools and Spas**  
**1105 Washington Blvd**  
**Pittsburgh, Pennsylvania 15206**  
**(412) 661- 7665**  
**Laboratory Analysis Report**

Lab ID No. 02-04041

**E-2**

**Lab# 128**

**Customer**

**Facility Name:** Hampton Inn & Suites North Huntingdon Irwin

**Address:** 8441 Country Club Drive  
North Huntingdon, PA 15642

**Matrix:** Recreational Water

**Source Type:** Pool

**Sample Collection**

**Date:** 9/22/25

**Time:** 8:37 AM

**Method:** Grab

**Sample Final Analysis**

**Date:** 9/25/25

**Time:** 10:00 AM

**Analyst:** AS

Accredited Analysis	Results	Reporting limit	Incubation	Date/Time	Analyst	Method
Escherichia Coli:	Absent	Absent	9/23/25	9:30 AM	JC	SM 9222G
Total coliforms:	1/100mls	2/100mls	9/23/25	9:30 AM	JC	SM 9222B
Standard plate count:	570/ml	200/ml	9/22/25	4:00 PM	SL	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time	Analyst	Method	
pH:	7.4 SU	7.2 - 7.8 SU	9/22/25	8:37 AM	JC	DPD
Chlorine:	1.0 mg/l	1.0 - 5.0 mg/l	9/22/25	8:37 AM	JC	DPD
Turbidity:	1 NTU	1 - 2 NTU	9/22/25	8:37 AM	JC	Visual

**Sample comments**

Andre Smith, Lead Supervisor

*Andre Smith*

( When exceeding reporting limit pool or spa is unfit)