



**Dream Pools and Spas**  
**1105 Washington Blvd**  
**Pittsburgh, Pennsylvania 15206**  
**(412) 661- 7665**  
**Laboratory Analysis Report**

Lab ID No. 02-04041

**E-2**

**Lab# 272**

**Customer**

**Facility Name:** Seven Springs Resort

**Address:** 777 Waterwheel Dr.  
Champion, PA 15622

**Matrix:** Recreational Water

**Source Type:** Pool

**Sample Collection**

**Date:** 2/16/26

**Time:** 10:41 AM

**Method:** Grab

**Sample Final Analysis**

**Date:** 2/18/26

**Time:** 10:30 AM

**Analyst:** AS

Accredited Analysis	Results	Reporting limit	Incubation	Date/Time	Analyst	Method
Escherichia Coli:	Absent	Absent	2/17/26	10:00 AM	SL	SM 9222G
Total coliforms:	0/100mls	2/100mls	2/17/26	10:00 AM	SL	SM 9222B
Standard plate count:	0/ml	200/ml	2/16/26	5:08 PM	SL	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time	Analyst	Method	
pH:	7.4 SU	7.2 - 7.8 SU	2/16/26	10:41 AM	JC	DPD
Chlorine:	5.0 mg/l	1.0 - 5.0 mg/l	2/16/26	10:41 AM	JC	DPD
Turbidity:	1 NTU	1 - 2 NTU	2/16/26	10:41 AM	JC	Visual

**Sample comments**

( When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor