



Dreams Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

PPS

Lab# 241

Customer

Facility Name: *Obama High School*

Address: *515 N. Highland Ave
Pittsburgh, PA 15206*

Matrix: *Recreational Water*

Source Type: *Pool Deep*

Sample Collection

Date: *8/18/25*

Time: *9:45 AM*

Method: *Grab*

Sample Final Analysis

Date: *8/21/25*

Time: *9:00 AM*

Analyst: *AS*

Accredited Analysis	Results	Rating	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	A	8/19/25	10:00 AM	EB	SM 9222G
Total coliforms:	0/100mls	A	8/19/25	10:00 AM	EB	SM 9222B
Standard plate count:	0/ml	A	8/18/25	4:20 PM	EB	SM 9215B

Field Analysis	Results	Rating	Date/Time		Analyst	Method
pH:	7.5 SU	A	8/18/25	9:45 AM	ZS	DPD
Chlorine:	1.5 mg/l	C	8/18/25	9:45 AM	ZS	DPD
Turbidity:	1 NTU	A	8/18/25	9:45 AM	ZS	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor