



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

N-16

Lab# 2772

Customer

Facility Name: *Laurel Grove*
Address: *4601 Spruce*
Gibsonia, PA 15044

Matrix: *Recreational Water*
Source Type: *Pool*

Sample Collection

Date: *6/4/25*
Time: *3:45 PM*
Method: *Grab*

Sample Final Analysis

Date: *6/6/25*
Time: *4:00 PM*
Analyst: *AS*

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	6/4/25	6:50 PM	SL	SM 9222G
Total coliforms:	0/100mls	2/100mls	6/4/25	6:50 PM	SL	SM 9222B
Standard plate count:	0/ml	200/ml	6/4/25	6:15 PM	SL	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.4 SU	7.2 - 7.8 SU	6/4/25	3:45 PM	SL	DPD
Chlorine:	2.0 mg/l	1.0 - 5.0 mg/l	6/4/25	3:45 PM	SL	DPD
Turbidity:	1 NTU	1 - 2 NTU	6/4/25	3:45 PM	SL	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

N-16

Lab# 2772

Customer

Facility Name: *Laurel Grove*
Address: *4601 Spruce*
Gibsonia, PA 15044

Matrix: *Recreational Water*

Source Type: *Pool*

Sample Collection

Date: *6/4/25*
Time: *3:45 PM*
Method: *Grab*

Sample Final Analysis

Date: *6/6/25*
Time: *4:00 PM*
Analyst: *AS*

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	6/4/25	6:50 PM	SL	SM 9222G
Total coliforms:	0/100mls	2/100mls	6/4/25	6:50 PM	SL	SM 9222B
Standard plate count:	0/ml	200/ml	6/4/25	6:15 PM	SL	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.4 SU	7.2 - 7.8 SU	6/4/25	3:45 PM	SL	DPD
Chlorine:	2.0 mg/l	1.0 - 5.0 mg/l	6/4/25	3:45 PM	SL	DPD
Turbidity:	1 NTU	1 - 2 NTU	6/4/25	3:45 PM	SL	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor