



**Dream Pools and Spas**  
**1105 Washington Blvd**  
**Pittsburgh, Pennsylvania 15206**  
**(412) 661- 7665**  
**Laboratory Analysis Report**

Lab ID No. 02-04041

**E - 11**

**Lab# 292**

**Customer**

**Facility Name:** Springhill Suites Latrobe

**Address:** 115 Arnold Palmer Drive  
Latrobe, PA 15650

**Matrix:** Recreational Water

**Source Type:** Pool

**Sample Collection**

**Date:** 6/16/25

**Time:** 1:40 PM

**Method:** Grab

**Sample Final Analysis**

**Date:** 6/19/25

**Time:** 10:00 AM

**Analyst:** AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	6/17/25	10:40 AM	EB	SM 9222G
Total coliforms:	0/100mls	2/100mls	6/17/25	10:40 AM	EB	SM 9222B
Standard plate count:	0/ml	200/ml	6/16/25	5:45 PM	EB	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.4 SU	7.2 - 7.8 SU	6/16/25	1:40 PM	JC	DPD
Chlorine:	7.5 mg/l	1.0 - 5.0 mg/l	6/16/25	1:40 PM	JC	DPD
Turbidity:	1 NTU	1 - 2 NTU	6/16/25	1:40 PM	JC	Visual

**Sample comments**

*Andre Smith*

( When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor



**Dream Pools and Spas**  
**1105 Washington Blvd**  
**Pittsburgh, Pennsylvania 15206**  
**(412) 661- 7665**  
**Laboratory Analysis Report**

Lab ID No. 02-04041

**E - 11**

**Lab# 292**

**Customer**

**Facility Name:** Springhill Suites Latrobe

**Address:** 115 Arnold Palmer Drive  
Latrobe, PA 15650

**Matrix:** Recreational Water

**Source Type:** Pool

**Sample Collection**

**Date:** 6/16/25

**Time:** 1:40 PM

**Method:** Grab

**Sample Final Analysis**

**Date:** 6/19/25

**Time:** 10:00 AM

**Analyst:** AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	6/17/25	10:40 AM	EB	SM 9222G
Total coliforms:	0/100mls	2/100mls	6/17/25	10:40 AM	EB	SM 9222B
Standard plate count:	0/ml	200/ml	6/16/25	5:45 PM	EB	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.4 SU	7.2 - 7.8 SU	6/16/25	1:40 PM	JC	DPD
Chlorine:	7.5 mg/l	1.0 - 5.0 mg/l	6/16/25	1:40 PM	JC	DPD
Turbidity:	1 NTU	1 - 2 NTU	6/16/25	1:40 PM	JC	Visual

**Sample comments**

*Andre Smith*

( When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor