



**Dream Pools and Spas**  
**1105 Washington Blvd**  
**Pittsburgh, Pennsylvania 15206**  
**(412) 661- 7665**  
**Laboratory Analysis Report**

Lab ID No. 02-04041

**S-3**

**Lab# 156**

**Customer**

Facility Name: Holiday Inn

Address: 3053 Washington Pike  
Bridgeville, PA 15017

Matrix: Recreational Water

Source Type: Pool

**Sample Collection**

Date: 9/22/25

Time: 1:01 PM

Method: Grab

**Sample Final Analysis**

Date: 9/25/25

Time: 10:00 AM

Analyst: AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	9/23/25	9:30 AM	JC	SM 9222G
Total coliforms:	0/100mls	2/100mls	9/23/25	9:30 AM	JC	SM 9222B
Standard plate count:	0/ml	200/ml	9/22/25	3:00 PM	SL	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.6 SU	7.2 - 7.8 SU	9/22/25	1:01 PM	GR	DPD
Chlorine:	3.0 mg/l	1.0 - 5.0 mg/l	9/22/25	1:01 PM	GR	DPD
Turbidity:	1 NTU	1 - 2 NTU	9/22/25	1:01 PM	GR	Visual

**Sample comments**

( When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor