



Dream Pools And Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

APM 1

Lab# 2732

Customer

American Pools Management
3261 Babcock Blvd.
Pittsburgh, PA 15237

Sample Collection

Date: 7/22/25
Time: 8:30 AM
Method: Grab

Sample Final Analysis

Date: 7/25/25
Time: 10:00 AM
Analyst: AS

Facility Name: Arsenal 201 Phase 2

Address: 3922 Foster St.
Pittsburgh, PA 15201

Matrix: Recreational Water

Source Type: Pool 2

| Accredited Analysis | Results | Reporting limit | Incubation Date/Time | | Analyst | Method |
|----------------------------|----------------|------------------------|-----------------------------|----------|----------------|---------------|
| Escherichia Coli: | Absent | Absent | 7/23/25 | 11:00 AM | AH | SM 9222G |
| Total coliforms: | 0/100mls | 2/100mls | 7/23/25 | 11:00 AM | AH | SM 9222B |
| Standard plate count: | 5700/ml | 200/ml | 7/22/25 | 5:00 PM | SL | SM 9215B |
| Field Analysis | Results | Reporting limit | Date/Time | | Analyst | Method |
| pH: | 7.8 SU | 7.2 - 7.8 SU | 7/22/25 | 8:30 AM | LM | DPD |
| Chlorine: | 2.0 mg/l | 1.0 - 5.0 mg/l | 7/22/25 | 8:30 AM | LM | DPD |
| Turbidity: | 1 NTU | 1 - 2 NTU | 7/22/25 | 8:30 AM | LM | Visual |

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor



Dream Pools And Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

APM 1

Lab# 2732

Customer

American Pools Management
3261 Babcock Blvd.
Pittsburgh, PA 15237

Sample Collection

Date: 7/22/25
Time: 8:30 AM
Method: Grab

Sample Final Analysis

Date: 7/25/25
Time: 10:00 AM
Analyst: AS

Facility Name: Arsenal 201 Phase 2

Address: 3922 Foster St.
Pittsburgh, PA 15201

Matrix: Recreational Water

Source Type: Pool 2

| Accredited Analysis | Results | Reporting limit | Incubation Date/Time | | Analyst | Method |
|----------------------------|----------------|------------------------|-----------------------------|----------|----------------|---------------|
| Escherichia Coli: | Absent | Absent | 7/23/25 | 11:00 AM | AH | SM 9222G |
| Total coliforms: | 0/100mls | 2/100mls | 7/23/25 | 11:00 AM | AH | SM 9222B |
| Standard plate count: | 5700/ml | 200/ml | 7/22/25 | 5:00 PM | SL | SM 9215B |
| Field Analysis | Results | Reporting limit | Date/Time | | Analyst | Method |
| pH: | 7.8 SU | 7.2 - 7.8 SU | 7/22/25 | 8:30 AM | LM | DPD |
| Chlorine: | 2.0 mg/l | 1.0 - 5.0 mg/l | 7/22/25 | 8:30 AM | LM | DPD |
| Turbidity: | 1 NTU | 1 - 2 NTU | 7/22/25 | 8:30 AM | LM | Visual |

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor