



**Dream Pools and Spas**  
**1105 Washington Blvd**  
**Pittsburgh, Pennsylvania 15206**  
**(412) 661- 7665**  
**Laboratory Analysis Report**

Lab ID No. 02-04041

**S-2**

**Lab# 011**

**Customer**

Facility Name: Athletic Club Carnegie Library of Homestead

Address: 510 East 10th Ave  
Munhall, PA 15120

Matrix: Recreational Water

Source Type: Pool

**Sample Collection**

Date: 1/5/26

Time: 8:30 AM

Method: Grab

**Sample Final Analysis**

Date: 1/8/26

Time: 10:30 AM

Analyst: AS

Accredited Analysis	Results	Reporting limit	Incubation	Date/Time	Analyst	Method
Escherichia Coli:	Absent	Absent	1/6/26	10:00 AM	JC	SM 9222G
Total coliforms:	0/100mls	2/100mls	1/6/26	10:00 AM	JC	SM 9222B
Standard plate count:	0/ml	200/ml	1/5/26	5:00 PM	SL	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time	Analyst	Method	
pH:	7.8 SU	7.2 - 7.8 SU	1/5/26	8:30 AM	SH	DPD
Chlorine:	2.0 mg/l	1.0 - 5.0 mg/l	1/5/26	8:30 AM	SH	DPD
Turbidity:	1 NTU	1 - 2 NTU	1/5/26	8:30 AM	SH	Visual

**Sample comments**

Andre Smith, Lead Supervisor

( When exceeding reporting limit pool or spa is unfit)