Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

S-15

Lab# 2497

Customer

Facility Name:	*Southpointe Golf Club*
Address:	*360 Southepointe Blvd. Canonsburg, PA 15317*
Matrix:	*Recreational Water*
Source Type:	*Pool*

Sample Collection

Date:	*7/30/25*
Time:	*2:17 PM*
Method:	*Grab*

Sample Final Analysis

Date:	*8/1/25*
Time:	*3:30 PM*
Analyst:	*AS*

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	7/30/25	5:30 PM	SL	SM 9222G
Total coliforms:	0/100mls	2/100mls	7/30/25	5:30 PM	SL	SM 9222B
Standard plate count:	0/ml	200/ml	7/30/25	4:50 PM	AS	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.4 SU	7.2 - 7.8 SU	7/30/25	2:17 PM	AF	DPD
Chlorine:	7.5 mg/l	1.0 - 5.0 mg/l	7/30/25	2:17 PM	AF	DPD
Turbidity:	1 NTU	1 - 2 NTU	7/30/25	2:17 PM	AF	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith

_____

Andre Smith, Lead Supervisor

Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

S-15

Lab# 2497

Customer

Facility Name: *Southpointe Golf Club*

Address: *360 Southepointe Blvd.*
                              Canonsburg, PA 15317

Matrix: *Recreational Water*

Source Type: *Pool*

Sample Collection

Date: 7/30/25
Time: 2:17 PM
Method: Grab

Sample Final Analysis

Date: 8/1/25
Time: 3:30 PM
Analyst: AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	7/30/25	5:30 PM	SL	SM 9222G
Total coliforms:	0/100mls	2/100mls	7/30/25	5:30 PM	SL	SM 9222B
Standard plate count:	0/ml	200/ml	7/30/25	4:50 PM	AS	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.4 SU	7.2 - 7.8 SU	7/30/25	2:17 PM	AF	DPD
Chlorine:	7.5 mg/l	1.0 - 5.0 mg/l	7/30/25	2:17 PM	AF	DPD
Turbidity:	1 NTU	1 - 2 NTU	7/30/25	2:17 PM	AF	Visual

Sample comments

Andre Smith

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor