Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

C-11

Lab# 465

Customer

		Sample Collection	
Facility Name:	*Towers Pool*	*Date:*	6/18/25
		Time:	11:50 AM
Address:	*1206 Bluff St.*	*Method:*	*Grab*
	Pittsburgh, PA 15282		
		Sample Final Analysis	
Matrix:	*Recreational Water*	*Date:*	*6/20/25*
		Time:	*3:30 PM*
Source Type:	*Pool Deep*	*Analyst:*	*AS*

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	6/18/25	5:40 PM	SL	SM 9222G
Total coliforms:	0/100mls	2/100mls	6/18/25	5:40 PM	SL	SM 9222B
Standard plate count:	0/ml	200/ml	6/18/25	5:39 PM	SL	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.6 SU	7.2 - 7.8 SU	6/18/25	11:50 AM	ZR	DPD
Chlorine:	3.0 mg/l	1.0 - 5.0 mg/l	6/18/25	11:50 AM	ZR	DPD
Turbidity:	1 NTU	1 - 2 NTU	6/18/25	11:50 AM	ZR	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor

Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

C-11

Lab# 465

Customer

		Sample Collection	
Facility Name:	*Towers Pool*	*Date:*	6/18/25
		Time:	11:50 AM
Address:	*1206 Bluff St.*	*Method:*	*Grab*
	Pittsburgh, PA 15282		
		Sample Final Analysis	
Matrix:	*Recreational Water*	*Date:*	*6/20/25*
		Time:	*3:30 PM*
Source Type:	*Pool Deep*	*Analyst:*	*AS*

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	6/18/25	5:40 PM	SL	SM 9222G
Total coliforms:	0/100mls	2/100mls	6/18/25	5:40 PM	SL	SM 9222B
Standard plate count:	0/ml	200/ml	6/18/25	5:39 PM	SL	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.6 SU	7.2 - 7.8 SU	6/18/25	11:50 AM	ZR	DPD
Chlorine:	3.0 mg/l	1.0 - 5.0 mg/l	6/18/25	11:50 AM	ZR	DPD
Turbidity:	1 NTU	1 - 2 NTU	6/18/25	11:50 AM	ZR	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor