

## Dream Pools and Spas 1105 Washington Blvd Pittsburgh, Pennsylvania 15206 (412) 661- 7665 Laboratory Analysis Report

Lab ID No. 02-04041

APM 3

Lab# 2595

<u>Customer</u> American Pools Management

3261 Babcock Blvd. Pittsburgh, PA 15237

Facility Name: The View@North Hills

Address: 1000 Johanna Drive

Pittsburgh, PA 15237

Matrix: Recreational Water

Results

Source Type: Pool

**Accredited Analysis** 

Sample Collection

Date: 6/16/25

Time: 11:28 AM

Method: Grab

Sample Final Analysis

**Incubation Date/Time** 

 Date:
 6/19/25

 Time:
 10:00 AM

 Analyst:
 AS

Analyst

Method

Escherichia Coli: Absent Absent 6/17/25 10:40 AM AΗ SM 9222G Total coliforms: 0/100mls 2/100mls 6/17/25 10:40 AM AΗ SM 9222B Standard plate count: 0/ml 200/ml 6/16/25 5:45 PM EB SM 9215B

**Reporting limit** 

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method	_
pH:	7.8 SU	7.2 - 7.8 SU	6/16/25	11:28 AM	ММ	DPD	
Chlorine:	5.0 mg/l	1.0 - 5.0 mg/l	6/16/25	11:28 AM	MM	DPD	
Turbidity:	1 NTU	1 - 2 NTU	6/16/25	11:28 AM	MM	Visual	

## Sample comments

( When exceeding reporting limit pool or spa is unfit)

andre Smith

Andre Smith, Lead Supervisor



## Dream Pools and Spas 1105 Washington Blvd Pittsburgh, Pennsylvania 15206 (412) 661- 7665 Laboratory Analysis Report

Lab ID No. 02-04041

APM 3

Lab# 2595

<u>Customer</u> American Pools Management

3261 Babcock Blvd. Pittsburgh, PA 15237

Facility Name: The View@North Hills

Address: 1000 Johanna Drive

Pittsburgh, PA 15237

Matrix: Recreational Water

Results

Source Type: Pool

**Accredited Analysis** 

Sample Collection

Date: 6/16/25

Time: 11:28 AM

Method: Grab

Sample Final Analysis

**Incubation Date/Time** 

 Date:
 6/19/25

 Time:
 10:00 AM

 Analyst:
 AS

Analyst

Method

Escherichia Coli: Absent Absent 6/17/25 10:40 AM AΗ SM 9222G Total coliforms: 0/100mls 2/100mls 6/17/25 10:40 AM AΗ SM 9222B Standard plate count: 0/ml 200/ml 6/16/25 5:45 PM EB SM 9215B

**Reporting limit** 

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method	_
pH:	7.8 SU	7.2 - 7.8 SU	6/16/25	11:28 AM	ММ	DPD	
Chlorine:	5.0 mg/l	1.0 - 5.0 mg/l	6/16/25	11:28 AM	MM	DPD	
Turbidity:	1 NTU	1 - 2 NTU	6/16/25	11:28 AM	MM	Visual	

## Sample comments

( When exceeding reporting limit pool or spa is unfit)

andre Smith

Andre Smith, Lead Supervisor