

Dream Pools and Spas 1105 Washington Blvd Pittsburgh, Pennsylvania 15206 (412) 661-7665 **Laboratory Analysis Report**

Lab ID No. 02-04041

E - 10

Lab# 202

Sample Collection Customer

Facility Name: L.A. Fitness Greensburg Date: 8/5/25 Time: 9:54 AM

Address: 3000 Lincoln Place Method: Grab

Greensburg, PA 15601

Matrix: Recreational Water

Source Type: Pool Sample Final Analysis

Date: 8/8/25

Time: 8:30 AM Analyst: AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	8/6/25	11:15 AM	АН	SM 9222G
Total coliforms:	0/100mls	2/100mls	8/6/25	11:15 AM	АН	SM 9222B
Standard plate count:	0/ml	200/ml	8/5/25	5:00 PM	AS	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method	_
pH:	7.6 SU	7.2 - 7.8 SU	8/5/25	9:54 AM	JC	DPD	
Chlorine:	3.0 mg/l	1.0 - 5.0 mg/l	8/5/25	9:54 AM	JC	DPD	
Turbidity:	1 NTU	1 - 2 NTU	8/5/25	9:54 AM	JC	Visual	

Sample comments

(When exceeding reporting limit pool or spa is unfit)

andre Smith

Andre Smith, Lead Supervisor



Dream Pools and Spas 1105 Washington Blvd Pittsburgh, Pennsylvania 15206 (412) 661-7665 **Laboratory Analysis Report**

Lab ID No. 02-04041

E - 10

Lab# 202

Sample Collection Customer

Facility Name: L.A. Fitness Greensburg Date: 8/5/25 Time: 9:54 AM

Address: 3000 Lincoln Place Method: Grab

Greensburg, PA 15601

Matrix: Recreational Water

Source Type: Pool Sample Final Analysis

Date: 8/8/25

Time: 8:30 AM Analyst: AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	8/6/25	11:15 AM	АН	SM 9222G
Total coliforms:	0/100mls	2/100mls	8/6/25	11:15 AM	АН	SM 9222B
Standard plate count:	0/ml	200/ml	8/5/25	5:00 PM	AS	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method	_
pH:	7.6 SU	7.2 - 7.8 SU	8/5/25	9:54 AM	JC	DPD	
Chlorine:	3.0 mg/l	1.0 - 5.0 mg/l	8/5/25	9:54 AM	JC	DPD	
Turbidity:	1 NTU	1 - 2 NTU	8/5/25	9:54 AM	JC	Visual	

Sample comments

(When exceeding reporting limit pool or spa is unfit)

andre Smith

Andre Smith, Lead Supervisor