



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

E-2

Lab# 079

Customer

Facility Name: Courtyard by Marriott
Address: 700 Powerline Dr.
Greensburg, PA 15601

Matrix: Recreational Water

Source Type: Spa

Sample Collection

Date: 12/23/25
Time: 1:24 PM
Method: Grab

Sample Final Analysis

Date: 12/26/25
Time: 11:00 AM
Analyst: AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time	Analyst	Method
---------------------	---------	-----------------	----------------------	---------	--------

Escherichia Coli:	Absent	Absent	12/24/25 10:30 AM	AS	SM 9222G
Total coliforms:	0/100mls	2/100mls	12/24/25 10:30 AM	AS	SM 9222B
Standard plate count:	0/ml	200/ml	12/23/25 5:30 PM	AS	SM 9215B

Additional Analysis	Results	Reporting limit	Incubation Date/Time	Analyst	Method
---------------------	---------	-----------------	----------------------	---------	--------

Fecal Streptococcus	0/100mls	2/100mls	12/24/25 12:00 PM	JC	SM 9230C
---------------------	----------	----------	-------------------	----	----------

Field Analysis	Results	Reporting limit	Date/Time	Analyst	Method
----------------	---------	-----------------	-----------	---------	--------

pH:	7.4 SU	7.2 - 7.8 SU	12/23/25 1:24 PM	EB	DPD
Chlorine:	5.0 mg/l	1.0 - 5.0 mg/l	12/23/25 1:24 PM	EB	DPD
Turbidity:	1 NTU	1 - 2 NTU	12/23/25 1:24 PM	EB	Visual

Sample comments

Andre Smith, Lead Supervisor

(When exceeding reporting limit pool or spa is unfit)