



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

E - 13

Lab# 2224

Customer

Facility Name: Gateway Heights
Address: 2249 Ramsey Road
Monroeville, PA 15146

Matrix: Recreational Water
Source Type: Baby Pool

Sample Collection

Date: 7/15/25
Time: 11:20 AM
Method: Grab

Sample Final Analysis

Date: 7/18/25
Time: 9:30 AM
Analyst: AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	7/16/25	9:35 AM	EB	SM 9222G
Total coliforms:	50/100mls	2/100mls	7/16/25	9:35 AM	EB	SM 9222B
Standard plate count:	570/ml	200/ml	7/15/25	3:28 PM	AH	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.4 SU	7.2 - 7.8 SU	7/15/25	11:20 AM	EH	DPD
Chlorine:	0.0 mg/l	1.0 - 5.0 mg/l	7/15/25	11:20 AM	EH	DPD
Turbidity:	1 NTU	1 - 2 NTU	7/15/25	11:20 AM	EH	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

E - 13

Lab# 2224

Customer

Facility Name: Gateway Heights
Address: 2249 Ramsey Road
Monroeville, PA 15146

Matrix: Recreational Water
Source Type: Baby Pool

Sample Collection

Date: 7/15/25
Time: 11:20 AM
Method: Grab

Sample Final Analysis

Date: 7/18/25
Time: 9:30 AM
Analyst: AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	7/16/25	9:35 AM	EB	SM 9222G
Total coliforms:	50/100mls	2/100mls	7/16/25	9:35 AM	EB	SM 9222B
Standard plate count:	570/ml	200/ml	7/15/25	3:28 PM	AH	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.4 SU	7.2 - 7.8 SU	7/15/25	11:20 AM	EH	DPD
Chlorine:	0.0 mg/l	1.0 - 5.0 mg/l	7/15/25	11:20 AM	EH	DPD
Turbidity:	1 NTU	1 - 2 NTU	7/15/25	11:20 AM	EH	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor