



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661-7665
Laboratory Analysis Report

Lab ID No. 02-04041

E - 12

Lab# 2169

Customer

Facility Name: Edgewood Club
Address: 1 Pennwood Ave.
Pittsburgh, PA 15218
Matrix: Recreational Water
Source Type: Deep End

Sample Collection

Date: 7/28/25
Time: 1:05 PM
Method: Grab

Sample Final Analysis

Date: 7/31/25
Time: 9:00 AM
Analyst: AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time	Analyst	Method
Escherichia Coli:	Absent	Absent	7/29/25	9:10 AM	EB
Total coliforms:	0/100mls	2/100mls	7/29/25	9:10 AM	EB
Standard plate count:	0/ml	200/ml	7/28/25	2:46 PM	EB

Field Analysis	Results	Reporting limit	Date/Time	Analyst	Method
pH:	7.4 SU	7.2 - 7.8 SU	7/28/25	1:05 PM	EH
Chlorine:	2.0 mg/l	1.0 - 5.0 mg/l	7/28/25	1:05 PM	EH
Turbidity:	1 NTU	1 - 2 NTU	7/28/25	1:05 PM	EH

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661-7665
Laboratory Analysis Report

Lab ID No. 02-04041

E - 12

Lab# 2169

Customer

Facility Name: Edgewood Club
Address: 1 Pennwood Ave.
Pittsburgh, PA 15218
Matrix: Recreational Water
Source Type: Deep End

Sample Collection

Date: 7/28/25
Time: 1:05 PM
Method: Grab

Sample Final Analysis

Date: 7/31/25
Time: 9:00 AM
Analyst: AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time	Analyst	Method
Escherichia Coli:	Absent	Absent	7/29/25	9:10 AM	EB
Total coliforms:	0/100mls	2/100mls	7/29/25	9:10 AM	EB
Standard plate count:	0/ml	200/ml	7/28/25	2:46 PM	EB

Field Analysis	Results	Reporting limit	Date/Time	Analyst	Method
pH:	7.4 SU	7.2 - 7.8 SU	7/28/25	1:05 PM	EH
Chlorine:	2.0 mg/l	1.0 - 5.0 mg/l	7/28/25	1:05 PM	EH
Turbidity:	1 NTU	1 - 2 NTU	7/28/25	1:05 PM	EH

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor