Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

N-10

Lab# 2445

Customer			*Sample Collection*	
Facility Name:	*Riverview Childrens*		*Date:*	6/17/25
			Time:	3:50 PM
Address:	*655 Sylvan Way*		*Method:*	*Grab*
	Verona, PA 15147			
			Sample Final Analysis	
Matrix:	*Recreational Water*		*Date:*	6/20/25
			Time:	9:00 AM
Source Type:	*Pool*		*Analyst:*	AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	6/18/25	11:00 AM	EB	SM 9222G
Total coliforms:	0/100mls	2/100mls	6/18/25	11:00 AM	EB	SM 9222B
Standard plate count:	225/ml	200/ml	6/17/25	5:00 PM	AS	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.4 SU	7.2 - 7.8 SU	6/17/25	3:50 PM	BH	DPD
Chlorine:	3.0 mg/l	1.0 - 5.0 mg/l	6/17/25	3:50 PM	BH	DPD
Turbidity:	1 NTU	1 - 2 NTU	6/17/25	3:50 PM	BH	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith

Andre Smith, Lead Supervisor

Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Customer

		Sample Collection	
Facility Name:	*Riverview Childrens*	*Date:*	6/17/25
		Time:	3:50 PM
Address:	*655 Sylvan Way*	*Method:*	*Grab*
	Verona, PA 15147		
		Sample Final Analysis	
Matrix:	*Recreational Water*	*Date:*	6/20/25
		Time:	9:00 AM
Source Type:	*Pool*	*Analyst:*	AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	6/18/25	11:00 AM	EB	SM 9222G
Total coliforms:	0/100mls	2/100mls	6/18/25	11:00 AM	EB	SM 9222B
Standard plate count:	225/ml	200/ml	6/17/25	5:00 PM	AS	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.4 SU	7.2 - 7.8 SU	6/17/25	3:50 PM	BH	DPD
Chlorine:	3.0 mg/l	1.0 - 5.0 mg/l	6/17/25	3:50 PM	BH	DPD
Turbidity:	1 NTU	1 - 2 NTU	6/17/25	3:50 PM	BH	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith

Andre Smith, Lead Supervisor