



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665

Lab ID No. 02-04041

W-2

Lab# 410

Laboratory Analysis Report

Customer

Facility Name: Fairfield Inn Airport
Address: 1004 Sutherland Dr
Pittsburgh, PA 15205

Matrix: Recreational Water

Source Type: Pool

Sample Collection

Date: 10/1/25
Time: 11:00 AM
Method: Grab

Sample Final Analysis

Date: 10/3/25
Time: 4:30 PM
Analyst: AS

Accredited Analysis	Results	Reporting limit	Incubation	Date/Time	Analyst	Method
Escherichia Coli:	Absent	Absent	10/1/25	4:00 PM	JC	SM 9222G
Total coliforms:	0/100mls	2/100mls	10/1/25	4:00 PM	JC	SM 9222B
Standard plate count:	0/ml	200/ml	10/1/25	3:10 PM	JC	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.4 SU	7.2 - 7.8 SU	10/1/25	11:00 AM	BH	DPD
Chlorine:	5.0 mg/l	1.0 - 5.0 mg/l	10/1/25	11:00 AM	BH	DPD
Turbidity:	1 NTU	1 - 2 NTU	10/1/25	11:00 AM	BH	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor