



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

N - 1

Lab# 164

Customer

Facility Name: *Holiday Inn Express - Butler*

Address: *203 North Duffy Rd
Butler, PA 16001*

Matrix: *Recreational Water*

Source Type: *Pool*

Sample Collection

Date: *11/10/25*

Time: *3:00 PM*

Method: *Grab*

Sample Final Analysis

Date: *11/13/25*

Time: *11:00 AM*

Analyst: *AS*

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	11/11/25	10:30 AM	JC	SM 9222G
Total coliforms:	0/100mls	2/100mls	11/11/25	10:30 AM	JC	SM 9222B
Standard plate count:	570/ml	200/ml	11/10/25	5:10 PM	AS	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.2 SU	7.2 - 7.8 SU	11/10/25	3:00 PM	BH	DPD
Chlorine:	0.0 mg/l	1.0 - 5.0 mg/l	11/10/25	3:00 PM	BH	DPD
Turbidity:	2 NTU	1 - 2 NTU	11/10/25	3:00 PM	BH	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor