Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Customer			*Sample Collection*	
Facility Name:	*Pine Twp. Spray Park*		*Date:*	*6/30/25*
			Time:	12:38 PM
Address:	*100 Pine Park Dr.*		*Method:*	*Grab*
	Wexford, PA 15090			
			Sample Final Analysis	
Matrix:	*Recreational Water*		*Date:*	*7/3/25*
			Time:	*9:30 AM*
Source Type:	*Spray Pad*		*Analyst:*	*AS*

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	7/1/25	9:30 AM	AH	SM 9222G
Total coliforms:	0/100mls	2/100mls	7/1/25	9:30 AM	AH	SM 9222B
Standard plate count:	190/ml	200/ml	6/30/25	3:44 PM	AH	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.6 SU	7.2 - 7.8 SU	6/30/25	12:38 PM	GR	DPD
Chlorine:	1.0 mg/l	1.0 - 5.0 mg/l	6/30/25	12:38 PM	GR	DPD
Turbidity:	1 NTU	1 - 2 NTU	6/30/25	12:38 PM	GR	Visual

Sample comments

Andre Smith

(When exceeding reporting limit pool or spa is unfit)

_____

Andre Smith, Lead Supervisor

Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

N-16

Lab# **2690**

Customer

Facility Name:	*Pine Twp. Spray Park*
Address:	*100 Pine Park Dr. Wexford, PA 15090*
Matrix:	*Recreational Water*
Source Type:	*Spray Pad*

Sample Collection

Date:	*6/30/25*
Time:	12:38 PM
Method:	*Grab*

Sample Final Analysis

Date:	*7/3/25*
Time:	*9:30 AM*
Analyst:	*AS*

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	7/1/25	9:30 AM	AH	SM 9222G
Total coliforms:	0/100mls	2/100mls	7/1/25	9:30 AM	AH	SM 9222B
Standard plate count:	190/ml	200/ml	6/30/25	3:44 PM	AH	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.6 SU	7.2 - 7.8 SU	6/30/25	12:38 PM	GR	DPD
Chlorine:	1.0 mg/l	1.0 - 5.0 mg/l	6/30/25	12:38 PM	GR	DPD
Turbidity:	1 NTU	1 - 2 NTU	6/30/25	12:38 PM	GR	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith

_____

Andre Smith, Lead Supervisor