



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

S-1

Lab# 444

Customer

Facility Name: *Highpoint Fitness*

Address: *1000 Higbee Dr.*
Bethel Park, PA 15102

Sample Collection

Date: *1/13/26*
Time: *11:47 AM*
Method: *Grab*

Matrix: *Recreational Water*

Source Type: *Therapy Pool*

Sample Final Analysis

Date: *1/16/26*
Time: *12:30 PM*
Analyst: *AS*

| Accredited Analysis | Results | Reporting limit | Incubation Date/Time | | Analyst | Method |
|-----------------------|----------|-----------------|----------------------|----------|---------|----------|
| Escherichia Coli: | Absent | Absent | 1/14/26 | 12:00 PM | JC | SM 9222G |
| Total coliforms: | 0/100mls | 2/100mls | 1/14/26 | 12:00 PM | JC | SM 9222B |
| Standard plate count: | 0/ml | 200/ml | 1/13/26 | 5:15 PM | SL | SM 9215B |

| Field Analysis | Results | Reporting limit | Date/Time | | Analyst | Method |
|----------------|----------|-----------------|-----------|----------|---------|--------|
| pH: | 7.6 SU | 7.2 - 7.8 SU | 1/13/26 | 11:47 AM | MM | DPD |
| Chlorine: | 3.0 mg/l | 1.0 - 5.0 mg/l | 1/13/26 | 11:47 AM | MM | DPD |
| Turbidity: | 1 NTU | 1 - 2 NTU | 1/13/26 | 11:47 AM | MM | Visual |

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor