



**Dreams Pools and Spas**  
**1105 Washington Blvd**  
**Pittsburgh, Pennsylvania 15206**  
**(412) 661- 7665**  
**Laboratory Analysis Report**

Lab ID No. 02-04041

**PPS**

**Lab# 252**

**Customer**

**Facility Name:** Perry Traditional Academy

**Address:** 3875 Perrysville Ave.  
Pittsburgh, PA 15214

**Matrix:** Recreational Water

**Source Type:** Pool Deep

**Sample Collection**

**Date:** 1/20/26

**Time:** 2:46 PM

**Method:** Grab

**Sample Final Analysis**

**Date:** 1/23/26

**Time:** 10:30 AM

**Analyst:** AS

Accredited Analysis	Results	Rating	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	A	1/21/26	11:00 AM	JC	SM 9222G
Total coliforms:	0/100mls	A	1/21/26	11:00 AM	JC	SM 9222B
Standard plate count:	0/ml	A	1/20/26	5:30 PM	SL	SM 9215B

Field Analysis	Results	Rating	Date/Time		Analyst	Method
pH:	7.6 SU	A	1/20/26	2:46 PM	MM	DPD
Chlorine:	3.0 mg/l	A	1/20/26	2:46 PM	MM	DPD
Turbidity:	1 NTU	A	1/20/26	2:46 PM	MM	Visual

**Sample comments**

Andre Smith, Lead Supervisor

( When exceeding reporting limit pool or spa is unfit)