



**Dream Pools and Spas**  
**1105 Washington Blvd**  
**Pittsburgh, Pennsylvania 15206**  
**(412) 661- 7665**  
**Laboratory Analysis Report**

Lab ID No. 02-04041

**N-10**

**Lab# 064**

**Customer**

Facility Name: *Comfort Inn - RIDC*  
Address: *180 Gamma Drive*  
*Pittsburgh, PA 15238*

Matrix: *Recreational Water*

Source Type: *Pool*

**Sample Collection**

Date: *6/17/25*  
Time: *2:20 PM*  
Method: *Grab*

**Sample Final Analysis**

Date: *6/20/25*  
Time: *9:00 AM*  
Analyst: *AS*

| Accredited Analysis   | Results  | Reporting limit | Incubation Date/Time |          | Analyst | Method   |
|-----------------------|----------|-----------------|----------------------|----------|---------|----------|
| Escherichia Coli:     | Absent   | Absent          | 6/18/25              | 11:00 AM | EB      | SM 9222G |
| Total coliforms:      | 0/100mls | 2/100mls        | 6/18/25              | 11:00 AM | EB      | SM 9222B |
| Standard plate count: | 0/ml     | 200/ml          | 6/17/25              | 5:00 PM  | AS      | SM 9215B |

| Field Analysis | Results   | Reporting limit | Date/Time |         | Analyst | Method |
|----------------|-----------|-----------------|-----------|---------|---------|--------|
| pH:            | 7.6 SU    | 7.2 - 7.8 SU    | 6/17/25   | 2:20 PM | BH      | DPD    |
| Chlorine:      | 10.0 mg/l | 1.0 - 5.0 mg/l  | 6/17/25   | 2:20 PM | BH      | DPD    |
| Turbidity:     | 1 NTU     | 1 - 2 NTU       | 6/17/25   | 2:20 PM | BH      | Visual |

**Sample comments**

( When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor



**Dream Pools and Spas**  
**1105 Washington Blvd**  
**Pittsburgh, Pennsylvania 15206**  
**(412) 661- 7665**  
**Laboratory Analysis Report**

Lab ID No. 02-04041

**N-10**

**Lab# 064**

**Customer**

Facility Name: *Comfort Inn - RIDC*  
  
Address: *180 Gamma Drive*  
*Pittsburgh, PA 15238*

Matrix: *Recreational Water*

Source Type: *Pool*

**Sample Collection**

Date: *6/17/25*  
Time: *2:20 PM*  
Method: *Grab*

**Sample Final Analysis**

Date: *6/20/25*  
Time: *9:00 AM*  
Analyst: *AS*

| Accredited Analysis   | Results  | Reporting limit | Incubation Date/Time |          | Analyst | Method   |
|-----------------------|----------|-----------------|----------------------|----------|---------|----------|
| Escherichia Coli:     | Absent   | Absent          | 6/18/25              | 11:00 AM | EB      | SM 9222G |
| Total coliforms:      | 0/100mls | 2/100mls        | 6/18/25              | 11:00 AM | EB      | SM 9222B |
| Standard plate count: | 0/ml     | 200/ml          | 6/17/25              | 5:00 PM  | AS      | SM 9215B |

| Field Analysis | Results   | Reporting limit | Date/Time |         | Analyst | Method |
|----------------|-----------|-----------------|-----------|---------|---------|--------|
| pH:            | 7.6 SU    | 7.2 - 7.8 SU    | 6/17/25   | 2:20 PM | BH      | DPD    |
| Chlorine:      | 10.0 mg/l | 1.0 - 5.0 mg/l  | 6/17/25   | 2:20 PM | BH      | DPD    |
| Turbidity:     | 1 NTU     | 1 - 2 NTU       | 6/17/25   | 2:20 PM | BH      | Visual |

**Sample comments**

( When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor