



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

E-2

Lab# 223

Customer

Facility Name: *McKeesport High School*

Address: *1960 Eden Park Blvd.*
McKeesport, PA 15132

Matrix: *Recreational Water*

Source Type: *Pool Deep*

Sample Collection

Date: *12/17/25*

Time: *10:04 AM*

Method: *Grab*

Sample Final Analysis

Date: *12/19/25*

Time: *5:00 PM*

Analyst: *AS*

| Accredited Analysis | Results | Reporting limit | Incubation Date/Time | | Analyst | Method |
|-----------------------|----------|-----------------|----------------------|---------|---------|----------|
| Escherichia Coli: | Absent | Absent | 12/17/25 | 4:30 PM | AS | SM 9222G |
| Total coliforms: | 0/100mls | 2/100mls | 12/17/25 | 4:30 PM | AS | SM 9222B |
| Standard plate count: | 0/ml | 200/ml | 12/17/25 | 4:30 PM | AS | SM 9215B |

| Field Analysis | Results | Reporting limit | Date/Time | | Analyst | Method |
|----------------|----------|-----------------|-----------|----------|---------|--------|
| pH: | 7.4 SU | 7.2 - 7.8 SU | 12/17/25 | 10:04 AM | SL | DPD |
| Chlorine: | 0.0 mg/l | 1.0 - 5.0 mg/l | 12/17/25 | 10:04 AM | SL | DPD |
| Turbidity: | 1 NTU | 1 - 2 NTU | 12/17/25 | 10:04 AM | SL | Visual |

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor