



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

C-1

Lab# 308

Customer

Facility Name: University of Pgh Bellefield Hall

Address: 315 South Bellefield Ave.
Pittsburgh, PA 15260

Matrix: Recreational Water

Source Type: Pool

Sample Collection

Date: 9/23/25

Time: 11:06 AM

Method: Grab

Sample Final Analysis

Date: 9/26/25

Time: 10:00 AM

Analyst: AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	9/24/25	9:10 AM	JC	SM 9222G
Total coliforms:	0/100mls	2/100mls	9/24/25	9:10 AM	JC	SM 9222B
Standard plate count:	0/ml	200/ml	9/23/25	2:00 PM	AS	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.4 SU	7.2 - 7.8 SU	9/23/25	11:06 AM	GR	DPD
Chlorine:	1.0 mg/l	1.0 - 5.0 mg/l	9/23/25	11:06 AM	GR	DPD
Turbidity:	1 NTU	1 - 2 NTU	9/23/25	11:06 AM	GR	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor