



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041
APM

Lab# 407

C1

Customer

American Pools Management
3261 Babcock Blvd.
Pittsburgh, PA 15237

Facility Name: Morrow Park
Address: 5250 Liberty Ave
Pittsburgh, PA 15224

Sample Collection

Date: 9/16/25
Time: 11:49 AM
Method: Grab

Matrix: Recreational Water
Source Type: Spa

Sample Final Analysis

Date: 9/19/25
Time: 9:00 AM
Analyst: AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	9/17/25	9:00 AM	JC	SM 9222G

Total coliforms:	0/100mls	2/100mls	9/17/25	9:00 AM	JC	SM 9222B
------------------	----------	----------	---------	---------	----	----------

Standard plate count:	0/ml	200/ml	9/16/25	2:00 PM	AS	SM 9215B
-----------------------	------	--------	---------	---------	----	----------

Additional Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
---------------------	---------	-----------------	----------------------	--	---------	--------

Fecal Streptococcus	0/100mls	2/100mls	9/17/25	10:00 AM	SL	SM 9230C
---------------------	----------	----------	---------	----------	----	----------

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
----------------	---------	-----------------	-----------	--	---------	--------

pH:	7.4 SU	7.2 - 7.8 SU	9/16/25	11:49 AM	GR	DPD
-----	--------	--------------	---------	----------	----	-----

Chlorine:	2.0 mg/l	1.0 - 5.0 mg/l	9/16/25	11:49 AM	GR	DPD
-----------	----------	----------------	---------	----------	----	-----

Turbidity:	1 NTU	1 - 2 NTU	9/16/25	11:49 AM	GR	Visual
------------	-------	-----------	---------	----------	----	--------

Sample comments

Andre Smith

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor