

Dream Pools and Spas 1105 Washington Blvd Pittsburgh, Pennsylvania 15206 (412) 661- 7665 Laboratory Analysis Report

Lab ID No. 02-04041

S-13

Lab# 2110

Grab

<u>Customer</u> <u>Sample Collection</u>

Facility Name: Clairton Rec Date: 7/21/25
Time: 8:00 AM

Address: 435 Fremont St. Method: Clairton, PA 15025

Matrix: Recreational Water Sample Final Analysis

Date: 7/24/25

Time: 10:00 AM
Source Type: Baby Pool Analyst: AS

Accredited Analysis Results **Reporting limit Incubation Date/Time Analyst** Method Escherichia Coli: Absent Absent 7/22/25 11:30 AM AHSM 9222G Total coliforms: 0/100mls 2/100mls 7/22/25 11:30 AM AΗ SM 9222B Standard plate count: 0/ml 200/ml 7/21/25 5:30 PM SL SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method	_
pH:	8.0 SU	7.2 - 7.8 SU	7/21/25	8:00 AM	SH	DPD	
Chlorine:	5.0 mg/l	1.0 - 5.0 mg/l	7/21/25	8:00 AM	SH	DPD	
Turbidity:	1 NTU	1 - 2 NTU	7/21/25	8:00 AM	SH	Visual	

Sample comments

(When exceeding reporting limit pool or spa is unfit)

andre Smith

Andre Smith, Lead Supervisor



Dream Pools and Spas 1105 Washington Blvd Pittsburgh, Pennsylvania 15206 (412) 661- 7665 Laboratory Analysis Report

Lab ID No. 02-04041

S-13

Lab# 2110

Grab

<u>Customer</u> <u>Sample Collection</u>

Facility Name: Clairton Rec Date: 7/21/25
Time: 8:00 AM

Address: 435 Fremont St. Method: Clairton, PA 15025

Matrix: Recreational Water Sample Final Analysis

Date: 7/24/25

Time: 10:00 AM
Source Type: Baby Pool Analyst: AS

Accredited Analysis Results **Reporting limit Incubation Date/Time Analyst** Method Escherichia Coli: Absent Absent 7/22/25 11:30 AM AHSM 9222G Total coliforms: 0/100mls 2/100mls 7/22/25 11:30 AM AΗ SM 9222B Standard plate count: 0/ml 200/ml 7/21/25 5:30 PM SL SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method	_
pH:	8.0 SU	7.2 - 7.8 SU	7/21/25	8:00 AM	SH	DPD	
Chlorine:	5.0 mg/l	1.0 - 5.0 mg/l	7/21/25	8:00 AM	SH	DPD	
Turbidity:	1 NTU	1 - 2 NTU	7/21/25	8:00 AM	SH	Visual	

Sample comments

(When exceeding reporting limit pool or spa is unfit)

andre Smith

Andre Smith, Lead Supervisor