



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

C-11

Lab# 165

Customer

Facility Name: *Holiday Inn Express - North Shore*

Address: *228 Federal St.
Pittsburgh, PA 15212*

Matrix: *Recreational Water*

Source Type: *Pool*

Sample Collection

Date: *7/8/25*

Time: *12:55 PM*

Method: *Grab*

Sample Final Analysis

Date: *7/11/25*

Time: *9:00 AM*

Analyst: *AS*

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	7/9/25	9:30 AM	EB	SM 9222G
Total coliforms:	0/100mls	2/100mls	7/9/25	9:30 AM	EB	SM 9222B
Standard plate count:	0/ml	200/ml	7/8/25	4:30 PM	AH	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	74.0 SU	7.2 - 7.8 SU	7/8/25	12:55 PM	LM	DPD
Chlorine:	10.0 mg/l	1.0 - 5.0 mg/l	7/8/25	12:55 PM	LM	DPD
Turbidity:	1 NTU	1 - 2 NTU	7/8/25	12:55 PM	LM	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

C-11

Lab# 165

Customer

Facility Name: *Holiday Inn Express - North Shore*

Address: *228 Federal St.
Pittsburgh, PA 15212*

Matrix: *Recreational Water*

Source Type: *Pool*

Sample Collection

Date: *7/8/25*

Time: *12:55 PM*

Method: *Grab*

Sample Final Analysis

Date: *7/11/25*

Time: *9:00 AM*

Analyst: *AS*

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	7/9/25	9:30 AM	EB	SM 9222G
Total coliforms:	0/100mls	2/100mls	7/9/25	9:30 AM	EB	SM 9222B
Standard plate count:	0/ml	200/ml	7/8/25	4:30 PM	AH	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	74.0 SU	7.2 - 7.8 SU	7/8/25	12:55 PM	LM	DPD
Chlorine:	10.0 mg/l	1.0 - 5.0 mg/l	7/8/25	12:55 PM	LM	DPD
Turbidity:	1 NTU	1 - 2 NTU	7/8/25	12:55 PM	LM	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor