



**Dream Pools and Spas**  
**1105 Washington Blvd**  
**Pittsburgh, Pennsylvania 15206**  
**(412) 661- 7665**  
**Laboratory Analysis Report**

Lab ID No. 02-04041

**E-2**

**Lab# 163**

**Customer**

Facility Name: *Holiday Inn Express*

Address: *3695 State Route 31*  
*Donegal, PA 15628*

Matrix: *Recreational Water*

Source Type: *Spa*

**Sample Collection**

Date: *1/12/26*

Time: *10:07 AM*

Method: *Grab*

**Sample Final Analysis**

Date: *1/15/26*

Time: *10:30 AM*

Analyst: *AS*

| Accredited Analysis | Results | Reporting limit | Incubation Date/Time | Analyst | Method |
|---------------------|---------|-----------------|----------------------|---------|--------|
|---------------------|---------|-----------------|----------------------|---------|--------|

|                   |        |        |                  |    |          |
|-------------------|--------|--------|------------------|----|----------|
| Escherichia Coli: | Absent | Absent | 1/13/26 10:00 AM | JC | SM 9222G |
|-------------------|--------|--------|------------------|----|----------|

|                  |          |          |                  |    |          |
|------------------|----------|----------|------------------|----|----------|
| Total coliforms: | 0/100mls | 2/100mls | 1/13/26 10:00 AM | JC | SM 9222B |
|------------------|----------|----------|------------------|----|----------|

|                       |      |        |                 |    |          |
|-----------------------|------|--------|-----------------|----|----------|
| Standard plate count: | 0/ml | 200/ml | 1/12/26 4:45 PM | SL | SM 9215B |
|-----------------------|------|--------|-----------------|----|----------|

| Additional Analysis | Results | Reporting limit | Incubation Date/Time | Analyst | Method |
|---------------------|---------|-----------------|----------------------|---------|--------|
|---------------------|---------|-----------------|----------------------|---------|--------|

|                     |          |          |                  |    |          |
|---------------------|----------|----------|------------------|----|----------|
| Fecal Streptococcus | 0/100mls | 2/100mls | 1/13/26 12:00 PM | JC | SM 9230C |
|---------------------|----------|----------|------------------|----|----------|

| Field Analysis | Results | Reporting limit | Date/Time | Analyst | Method |
|----------------|---------|-----------------|-----------|---------|--------|
|----------------|---------|-----------------|-----------|---------|--------|

|     |        |              |                  |    |     |
|-----|--------|--------------|------------------|----|-----|
| pH: | 7.4 SU | 7.2 - 7.8 SU | 1/12/26 10:07 AM | JC | DPD |
|-----|--------|--------------|------------------|----|-----|

|           |           |                |                  |    |     |
|-----------|-----------|----------------|------------------|----|-----|
| Chlorine: | 10.0 mg/l | 1.0 - 5.0 mg/l | 1/12/26 10:07 AM | JC | DPD |
|-----------|-----------|----------------|------------------|----|-----|

|            |       |           |                  |    |        |
|------------|-------|-----------|------------------|----|--------|
| Turbidity: | 1 NTU | 1 - 2 NTU | 1/12/26 10:07 AM | JC | Visual |
|------------|-------|-----------|------------------|----|--------|

**Sample comments**

Andre Smith, Lead Supervisor

( When exceeding reporting limit pool or spa is unfit)