



**Dream Pools and Spas**  
**1105 Washington Blvd**  
**Pittsburgh, Pennsylvania 15206**  
**(412) 661- 7665**  
**Laboratory Analysis Report**

Lab ID No. 02-04041

**W-1**

**Lab# 093**

**Customer**

Facility Name: Doubletree Hotel  
Address: 8402 University Blvd.  
Moon, PA 15108

Matrix: Recreational Water

Source Type: Pool

**Sample Collection**

Date: 10/27/25  
Time: 9:35 AM  
Method: Grab

**Sample Final Analysis**

Date: 10/30/25  
Time: 10:30 AM  
Analyst: AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	10/28/25	10:00 AM	JC	SM 9222G
Total coliforms:	0/100mls	2/100mls	10/28/25	10:00 AM	JC	SM 9222B
Standard plate count:	0/ml	200/ml	10/27/25	5:15 PM	AS	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.2 SU	7.2 - 7.8 SU	10/27/25	9:35 AM	AMH	DPD
Chlorine:	3.0 mg/l	1.0 - 5.0 mg/l	10/27/25	9:35 AM	AMH	DPD
Turbidity:	1 NTU	1 - 2 NTU	10/27/25	9:35 AM	AMH	Visual

**Sample comments**

*Andre Smith*

( When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor