



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661-7665
Laboratory Analysis Report

Lab ID No. 02-04041

W-10

Lab# 173

Customer

Facility Name: Hopewell Middle School

Address: 2354 Brodhead Rd
Aliquippa, PA 15001

Matrix: Recreational Water

Source Type: Pool

Sample Collection

Date: 7/7/25

Time: 11:34 AM

Method: Grab

Sample Final Analysis

Date: 7/10/25

Time: 9:30 AM

Analyst: AS

| Accredited Analysis | Results | Reporting limit | Incubation Date/Time | Analyst | Method | |
|-----------------------|----------|-----------------|----------------------|----------|--------|----------|
| Escherichia Coli: | Absent | Absent | 7/8/25 | 11:15 AM | EB | SM 9222G |
| Total coliforms: | 0/100mls | 2/100mls | 7/8/25 | 11:15 AM | EB | SM 9222B |
| Standard plate count: | 0/ml | 200/ml | 7/7/25 | 7:00 PM | SL | SM 9215B |

| Field Analysis | Results | Reporting limit | Date/Time | Analyst | Method | |
|----------------|----------|-----------------|-----------|----------|--------|--------|
| pH: | 8.0 SU | 7.2 - 7.8 SU | 7/7/25 | 11:34 AM | AH | DPD |
| Chlorine: | 7.5 mg/l | 1.0 - 5.0 mg/l | 7/7/25 | 11:34 AM | AH | DPD |
| Turbidity: | 1 NTU | 1 - 2 NTU | 7/7/25 | 11:34 AM | AH | Visual |

Sample comments

(When exceeding reporting limit pool or spa is unfit)

A handwritten signature in black ink that reads "Andre Smith".

Andre Smith, Lead Supervisor



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661-7665
Laboratory Analysis Report

Lab ID No. 02-04041

W-10

Lab# 173

Customer

Facility Name: Hopewell Middle School

Address: 2354 Brodhead Rd
Aliquippa, PA 15001

Matrix: Recreational Water

Source Type: Pool

Sample Collection

Date: 7/7/25

Time: 11:34 AM

Method: Grab

Sample Final Analysis

Date: 7/10/25

Time: 9:30 AM

Analyst: AS

| Accredited Analysis | Results | Reporting limit | Incubation Date/Time | Analyst | Method | |
|-----------------------|----------|-----------------|----------------------|----------|--------|----------|
| Escherichia Coli: | Absent | Absent | 7/8/25 | 11:15 AM | EB | SM 9222G |
| Total coliforms: | 0/100mls | 2/100mls | 7/8/25 | 11:15 AM | EB | SM 9222B |
| Standard plate count: | 0/ml | 200/ml | 7/7/25 | 7:00 PM | SL | SM 9215B |

| Field Analysis | Results | Reporting limit | Date/Time | Analyst | Method | |
|----------------|----------|-----------------|-----------|----------|--------|--------|
| pH: | 8.0 SU | 7.2 - 7.8 SU | 7/7/25 | 11:34 AM | AH | DPD |
| Chlorine: | 7.5 mg/l | 1.0 - 5.0 mg/l | 7/7/25 | 11:34 AM | AH | DPD |
| Turbidity: | 1 NTU | 1 - 2 NTU | 7/7/25 | 11:34 AM | AH | Visual |

Sample comments

(When exceeding reporting limit pool or spa is unfit)

A handwritten signature in black ink that reads "Andre Smith".

Andre Smith, Lead Supervisor