Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Customer

Facility Name:	Treesdale Golf & CC
Address:	1 Arnold Palmer Dr. Gibsonia, PA 15044
Matrix:	Recreational Water
Source Type:	Baby Pool

Sample Collection

Date:	6/9/25
Time:	1:18 PM
Method:	Grab

Sample Final Analysis

Date:	6/12/25
Time:	9:30 AM
Analyst:	AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	6/10/25	9:40 AM	AH	SM 9222G
Total coliforms:	0/100mls	2/100mls	6/10/25	9:40 AM	AH	SM 9222B
Standard plate count:	90/ml	200/ml	6/9/25	3:29 PM	EB	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.6 SU	7.2 - 7.8 SU	6/9/25	1:18 PM	GR	DPD
Chlorine:	2.0 mg/l	1.0 - 5.0 mg/l	6/9/25	1:18 PM	GR	DPD
Turbidity:	1 NTU	1 - 2 NTU	6/9/25	1:18 PM	GR	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith

Andre Smith, Lead Supervisor

B & R Pools and Swim Shop

Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

N-16

Lab# **2534**

Customer	**_Sample Collection_**
Facility Name: *Treesdale Golf & CC*	*Date:* 6/9/25
	Time: 1:18 PM
Address: *1 Arnold Palmer Dr.*	*Method:* *Grab*
Gibsonia, PA 15044	
	Sample Final Analysis
Matrix: *Recreational Water*	*Date:* 6/12/25
	Time: 9:30 AM
Source Type: *Baby Pool*	*Analyst:* AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	6/10/25	9:40 AM	AH	SM 9222G
Total coliforms:	0/100mls	2/100mls	6/10/25	9:40 AM	AH	SM 9222B
Standard plate count:	90/ml	200/ml	6/9/25	3:29 PM	EB	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.6 SU	7.2 - 7.8 SU	6/9/25	1:18 PM	GR	DPD
Chlorine:	2.0 mg/l	1.0 - 5.0 mg/l	6/9/25	1:18 PM	GR	DPD
Turbidity:	1 NTU	1 - 2 NTU	6/9/25	1:18 PM	GR	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith

_____

Andre Smith, Lead Supervisor