



Dreams Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

PPS

Lab# 019

Customer

Facility Name: *Baxter Building*

Address: *925 Brushton Ave
Pittsburgh, PA 15208*

Matrix: *Recreational Water*

Source Type: *Pool Shallow*

Sample Collection

Date: *10/14/25*

Time: *9:42 AM*

Method: *Grab*

Sample Final Analysis

Date: *10/17/25*

Time: *10:30 AM*

Analyst: *AS*

Accredited Analysis	Results	Rating	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	A	10/15/25	10:00 AM	SL	SM 9222G
Total coliforms:	0/100mls	A	10/15/25	10:00 AM	SL	SM 9222B
Standard plate count:	0/ml	A	10/14/25	3:50 PM	SL	SM 9215B

Field Analysis	Results	Rating	Date/Time		Analyst	Method
pH:	7.8 SU	C	10/14/25	9:42 AM	MM	DPD
Chlorine:	2.0 mg/l	B	10/14/25	9:42 AM	MM	DPD
Turbidity:	1 NTU	A	10/14/25	9:42 AM	MM	Visual

Sample comments

Andre Smith

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor