



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

SERVICE

Lab# 425

Customer

Facility Name: Chatham University
Address: 1 Woodland Rd.
Pittsburgh, PA 15232

Matrix: Recreational Water
Source Type: Pool Shallow

Sample Collection

Date: 9/8/25
Time: 10:00 AM
Method: Grab

Sample Final Analysis

Date: 9/11/25
Time: 10:00 AM
Analyst: 1/0/00

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	9/9/25	9:00 AM	SL	SM 9222G
Total coliforms:	0/100mls	2/100mls	9/9/25	9:00 AM	SL	SM 9222B
Standard plate count:	0/ml	200/ml	9/8/25	5:30 PM	AS	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.5 SU	7.2 - 7.8 SU	9/8/25	10:00 AM	MB	DPD
Chlorine:	2.4 mg/l	1.0 - 5.0 mg/l	9/8/25	10:00 AM	MB	DPD
Turbidity:	1 NTU	1 - 2 NTU	9/8/25	10:00 AM	MB	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor