



**Dream Pools and Spas**  
**1105 Washington Blvd**  
**Pittsburgh, Pennsylvania 15206**  
**(412) 661- 7665**  
**Laboratory Analysis Report**

Lab ID No. 02-04041

**S-2**

**Lab# 359**

**Customer**

**Facility Name:** YMCA - Mon-Valley  
**Address:** 101 Taylor Run Road  
Monongahela, PA 15063

**Matrix:** Recreational Water

**Source Type:** Pool

**Sample Collection**

**Date:** 2/9/26  
**Time:** 2:40 PM  
**Method:** Grab

**Sample Final Analysis**

**Date:** 2/12/26  
**Time:** 10:30 AM  
**Analyst:** AS

Accredited Analysis	Results	Reporting limit	Incubation	Date/Time	Analyst	Method
Escherichia Coli:	Absent	Absent	2/10/26	10:00 AM	SL	SM 9222G
Total coliforms:	0/100mls	2/100mls	2/10/26	10:00 AM	SL	SM 9222B
Standard plate count:	0/ml	200/ml	2/9/26	5:20 PM	SL	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time	Analyst	Method	
pH:	8.0 SU	7.2 - 7.8 SU	2/9/26	2:40 PM	SH	DPD
Chlorine:	2.0 mg/l	1.0 - 5.0 mg/l	2/9/26	2:40 PM	SH	DPD
Turbidity:	1 NTU	1 - 2 NTU	2/9/26	2:40 PM	SH	Visual

**Sample comments**

( When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor