



**Dream Pools and Spas  
1105 Washington Blvd  
Pittsburgh, Pennsylvania 15206  
(412) 661-7665  
Laboratory Analysis Report**

Lab ID No. 02-04041

E - 11

Lab# 163

**Customer**

Facility Name: Holiday Inn Express

Address: 3695 State Rd, RT 31  
Donegal, PA 15628

Matrix: Recreational Water

Source Type: Spa

**Sample Collection**

Date: 8/11/25

Time: 9:43 AM

Method: Grab

**Sample Final Analysis**

Date: 8/14/25

Time: 9:00 AM

Analyst: AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time	Analyst	Method
Escherichia Coli:	Absent	Absent	8/12/25	10:00 AM	EB
Total coliforms:	0/100mls	2/100mls	8/12/25	10:00 AM	EB
Standard plate count:	0/ml	200/ml	8/11/25	5:20 PM	AH

Additional Analysis	Results	Reporting limit	Incubation Date/Time	Analyst	Method
Fecal Streptococcus	0/100mls	2/100mls	8/12/25	11:25 AM	EB

Field Analysis	Results	Reporting limit	Date/Time	Analyst	Method
pH:	7.0 SU	7.2 - 7.8 SU	8/11/25	9:43 AM	JC
Chlorine:	3.0 mg/l	1.0 - 5.0 mg/l	8/11/25	9:43 AM	JC
Turbidity:	1 NTU	1 - 2 NTU	8/11/25	9:43 AM	JC

**Sample comments**

*Andre Smith*

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor



**Dream Pools and Spas  
1105 Washington Blvd  
Pittsburgh, Pennsylvania 15206  
(412) 661-7665  
Laboratory Analysis Report**

Lab ID No. 02-04041

E - 11

Lab# 163

**Customer**

Facility Name: Holiday Inn Express

Address: 3695 State Rd, RT 31  
Donegal, PA 15628

Matrix: Recreational Water

Source Type: Spa

**Sample Collection**

Date: 8/11/25

Time: 9:43 AM

Method: Grab

**Sample Final Analysis**

Date: 8/14/25

Time: 9:00 AM

Analyst: AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time	Analyst	Method
Escherichia Coli:	Absent	Absent	8/12/25	10:00 AM	EB
Total coliforms:	0/100mls	2/100mls	8/12/25	10:00 AM	EB
Standard plate count:	0/ml	200/ml	8/11/25	5:20 PM	AH

Additional Analysis	Results	Reporting limit	Incubation Date/Time	Analyst	Method
Fecal Streptococcus	0/100mls	2/100mls	8/12/25	11:25 AM	EB

Field Analysis	Results	Reporting limit	Date/Time	Analyst	Method
pH:	7.0 SU	7.2 - 7.8 SU	8/11/25	9:43 AM	JC
Chlorine:	3.0 mg/l	1.0 - 5.0 mg/l	8/11/25	9:43 AM	JC
Turbidity:	1 NTU	1 - 2 NTU	8/11/25	9:43 AM	JC

**Sample comments**

*Andre Smith*

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor