



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

S-14

Lab# 2539

Customer

Facility Name: Upper St. Clair Rec.
Address: 1551 Mayview Rd.
Pittsburgh, PA 15241

Sample Collection

Date: 6/30/25
Time: 2:51 PM
Method: Grab

Matrix: Recreational Water
Source Type: Slide Deep

Sample Final Analysis

Date: 7/3/25
Time: 9:30 AM
Analyst: AS

| Accredited Analysis | Results | Reporting limit | Incubation Date/Time | | Analyst | Method |
|-----------------------|----------|-----------------|----------------------|----------|---------|----------|
| Escherichia Coli: | Absent | Absent | 7/1/25 | 10:30 AM | EB | SM 9222G |
| Total coliforms: | 0/100mls | 2/100mls | 7/1/25 | 10:30 AM | EB | SM 9222B |
| Standard plate count: | 0/ml | 200/ml | 6/30/25 | 6:00 PM | EB | SM 9215B |

| Field Analysis | Results | Reporting limit | Date/Time | | Analyst | Method |
|----------------|----------|-----------------|-----------|---------|---------|--------|
| pH: | 7.0 SU | 7.2 - 7.8 SU | 6/30/25 | 2:51 PM | AF | DPD |
| Chlorine: | 2.0 mg/l | 1.0 - 5.0 mg/l | 6/30/25 | 2:51 PM | AF | DPD |
| Turbidity: | 1 NTU | 1 - 2 NTU | 6/30/25 | 2:51 PM | AF | Visual |

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

S-14

Lab# 2539

Customer

Facility Name: Upper St. Clair Rec.
Address: 1551 Mayview Rd.
Pittsburgh, PA 15241

Sample Collection

Date: 6/30/25
Time: 2:51 PM
Method: Grab

Matrix: Recreational Water
Source Type: Slide Deep

Sample Final Analysis

Date: 7/3/25
Time: 9:30 AM
Analyst: AS

| Accredited Analysis | Results | Reporting limit | Incubation Date/Time | | Analyst | Method |
|-----------------------|----------|-----------------|----------------------|----------|---------|----------|
| Escherichia Coli: | Absent | Absent | 7/1/25 | 10:30 AM | EB | SM 9222G |
| Total coliforms: | 0/100mls | 2/100mls | 7/1/25 | 10:30 AM | EB | SM 9222B |
| Standard plate count: | 0/ml | 200/ml | 6/30/25 | 6:00 PM | EB | SM 9215B |

| Field Analysis | Results | Reporting limit | Date/Time | | Analyst | Method |
|----------------|----------|-----------------|-----------|---------|---------|--------|
| pH: | 7.0 SU | 7.2 - 7.8 SU | 6/30/25 | 2:51 PM | AF | DPD |
| Chlorine: | 2.0 mg/l | 1.0 - 5.0 mg/l | 6/30/25 | 2:51 PM | AF | DPD |
| Turbidity: | 1 NTU | 1 - 2 NTU | 6/30/25 | 2:51 PM | AF | Visual |

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor