

Dream Pools and Spas 1105 Washington Blvd Pittsburgh, Pennsylvania 15206 (412) 661- 7665 Laboratory Analysis Report

W-12

Lab ID No. 02-04041

Lab# 008

<u>Customer</u> <u>Sample Collection</u>

Facility Name: Allegheny Valley School Date: 7/2/25 Time: 9:00 AM

Address: 315 W. Prospect Ave Method: Grab

Pittsburgh, PA 15205

Matrix: Recreational Water Sample Final Analysis

Date: 7/4/25

Source Type: Pool Time: 3:30 PM
Analyst: AS

Accredited Analysis Results Reporting limit **Incubation Date/Time Analyst** Method 3:00 PM Escherichia Coli: Absent Absent 7/2/25 EΒ SM 9222G Total coliforms: 10/100mls 2/100mls 7/2/25 3:00 PM EΒ SM 9222B Standard plate count: 5700/ml 200/ml 7/2/25 3:00 PM AΗ SM 9215B

| Field Analysis | Results | Reporting limit | | Date/Time | Analyst | Method |
|----------------|----------|-----------------|--------|-----------|---------|--------|
| рН: | 7.0 SU | 7.2 - 7.8 SU | 7/2/25 | 9:00 AM | VH | DPD |
| Chlorine: | 0.0 mg/l | 1.0 - 5.0 mg/l | 7/2/25 | 9:00 AM | VH | DPD |
| Turbidity: | 1 NTU | 1 - 2 NTU | 7/2/25 | 9:00 AM | VH | Visual |

Sample comments

(When exceeding reporting limit pool or spa is unfit)

andre Smith

Andre Smith, Lead Supervisor



Dream Pools and Spas 1105 Washington Blvd Pittsburgh, Pennsylvania 15206 (412) 661- 7665 Laboratory Analysis Report

W-12

Lab ID No. 02-04041

Lab# 008

<u>Customer</u> <u>Sample Collection</u>

Facility Name: Allegheny Valley School Date: 7/2/25 Time: 9:00 AM

Address: 315 W. Prospect Ave Method: Grab

Pittsburgh, PA 15205

Matrix: Recreational Water Sample Final Analysis

Date: 7/4/25

Source Type: Pool Time: 3:30 PM
Analyst: AS

Accredited Analysis Results Reporting limit **Incubation Date/Time Analyst** Method 3:00 PM Escherichia Coli: Absent Absent 7/2/25 EΒ SM 9222G Total coliforms: 10/100mls 2/100mls 7/2/25 3:00 PM EΒ SM 9222B Standard plate count: 5700/ml 200/ml 7/2/25 3:00 PM AΗ SM 9215B

| Field Analysis | Results | Reporting limit | | Date/Time | Analyst | Method |
|----------------|----------|-----------------|--------|-----------|---------|--------|
| рН: | 7.0 SU | 7.2 - 7.8 SU | 7/2/25 | 9:00 AM | VH | DPD |
| Chlorine: | 0.0 mg/l | 1.0 - 5.0 mg/l | 7/2/25 | 9:00 AM | VH | DPD |
| Turbidity: | 1 NTU | 1 - 2 NTU | 7/2/25 | 9:00 AM | VH | Visual |

Sample comments

(When exceeding reporting limit pool or spa is unfit)

andre Smith

Andre Smith, Lead Supervisor