

Dream Pools and Spas 1105 Washington Blvd Pittsburgh, Pennsylvania 15206 (412) 661-7665 **Laboratory Analysis Report**

Lab ID No. 02-04041

N-14

Lab# 2719

Customer

Facility Name: Meeder Flats

Spa

Address:

1000 Strand Road

Cranberry, PA 16066

Matrix:

Recreational Water

Source Type:

Sample Final Analysis Date:

> Time: Analyst:

Date:

Time:

Method:

Sample Collection

8/14/25 9:00 AM

AS

8/11/25

3:32 PM

Grab

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	8/12/25	11:00 AM	EB	SM 9222G
Total coliforms:	0/100mls	2/100mls	8/12/25	11:00 AM	EB	SM 9222B
Standard plate count:	0/ml	200/ml	8/11/25	6:00 PM	SL	SM 9215B
Additional Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Fecal Streptococcus	0/100mls	2/100mls	8/12/25	11:25 AM	EB	SM 9230C

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
рН:	7.3 SU	7.2 - 7.8 SU	8/11/25	3:32 PM	ZS	DPD
Chlorine:	4.0 mg/l	1.0 - 5.0 mg/l	8/11/25	3:32 PM	ZS	DPD
Turbidity:	1 NTU	1 - 2 NTU	8/11/25	3:32 PM	ZS	Visual

Sample comments

andre Smith



Dream Pools and Spas 1105 Washington Blvd Pittsburgh, Pennsylvania 15206 (412) 661-7665 **Laboratory Analysis Report**

Lab ID No. 02-04041

N-14

Lab# 2719

Customer

Facility Name: Meeder Flats

Spa

Address:

1000 Strand Road

Cranberry, PA 16066

Matrix:

Recreational Water

Source Type:

Sample Final Analysis Date:

> Time: Analyst:

Date:

Time:

Method:

Sample Collection

8/14/25 9:00 AM

AS

8/11/25

3:32 PM

Grab

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	8/12/25	11:00 AM	EB	SM 9222G
Total coliforms:	0/100mls	2/100mls	8/12/25	11:00 AM	EB	SM 9222B
Standard plate count:	0/ml	200/ml	8/11/25	6:00 PM	SL	SM 9215B
Additional Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Fecal Streptococcus	0/100mls	2/100mls	8/12/25	11:25 AM	EB	SM 9230C

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
рН:	7.3 SU	7.2 - 7.8 SU	8/11/25	3:32 PM	ZS	DPD
Chlorine:	4.0 mg/l	1.0 - 5.0 mg/l	8/11/25	3:32 PM	ZS	DPD
Turbidity:	1 NTU	1 - 2 NTU	8/11/25	3:32 PM	ZS	Visual

Sample comments

andre Smith