



**Dream Pools and Spas**  
**1105 Washington Blvd**  
**Pittsburgh, Pennsylvania 15206**  
**(412) 661- 7665**  
**Laboratory Analysis Report**

Lab ID No. 02-04041

**N-12**

**Lab# 2025**

**Customer**

**Facility Name:** *Bairel Center*  
**Address:** *2565 Nicholson Road*  
*Sewickley, PA 15143*

**Sample Collection**

**Date:** *8/26/25*  
**Time:** *3:06 PM*  
**Method:** *Grab*

**Sample Final Analysis**

**Date:** *8/29/25*  
**Time:** *10:30 AM*  
**Analyst:** *1/0/00*

**Matrix:** *Recreational Water*  
**Source Type:** *Pool*

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	8/27/25	12:00 PM	AS	SM 9222G
Total coliforms:	0/100mls	2/100mls	8/27/25	12:00 PM	AS	SM 9222B
Standard plate count:	0/ml	200/ml	8/26/25	5:30 PM	AS	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.4 SU	7.2 - 7.8 SU	8/26/25	3:06 PM	MM	DPD
Chlorine:	3.0 mg/l	1.0 - 5.0 mg/l	8/26/25	3:06 PM	MM	DPD
Turbidity:	1 NTU	1 - 2 NTU	8/26/25	3:06 PM	MM	Visual

**Sample comments**

*Andre Smith*

( When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor