



**Dream Pools and Spas**  
**1105 Washington Blvd**  
**Pittsburgh, Pennsylvania 15206**  
**(412) 661- 7665**  
**Laboratory Analysis Report**

Lab ID No. 02-04041

**N-11**

**Lab# 147**

**Customer**

Facility Name: *Highland School District*  
Address: *1500 Pacific Ave.*  
*Natrona Heights, PA 15065*

Matrix: *Recreational Water*

Source Type: *Shallow End*

**Sample Collection**

Date: *7/1/25*  
Time: *2:10 PM*  
Method: *Grab*

**Sample Final Analysis**

Date: *7/4/25*  
Time: *9:30 AM*  
Analyst: *AS*

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	7/2/25	10:40 AM	EB	SM 9222G
Total coliforms:	0/100mls	2/100mls	7/2/25	10:40 AM	EB	SM 9222B
Standard plate count:	0/ml	200/ml	7/1/25	5:37 PM	SL	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.8 SU	7.2 - 7.8 SU	7/1/25	2:10 PM	SH	DPD
Chlorine:	2.0 mg/l	1.0 - 5.0 mg/l	7/1/25	2:10 PM	SH	DPD
Turbidity:	1 NTU	1 - 2 NTU	7/1/25	2:10 PM	SH	Visual

**Sample comments**

( When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor



**Dream Pools and Spas**  
**1105 Washington Blvd**  
**Pittsburgh, Pennsylvania 15206**  
**(412) 661- 7665**  
**Laboratory Analysis Report**

Lab ID No. 02-04041

**N-11**

**Lab# 147**

**Customer**

**Facility Name:** Highland School District  
**Address:** 1500 Pacific Ave.  
Natrona Heights, PA 15065

**Matrix:** Recreational Water

**Source Type:** Shallow End

**Sample Collection**

**Date:** 7/1/25  
**Time:** 2:10 PM  
**Method:** Grab

**Sample Final Analysis**

**Date:** 7/4/25  
**Time:** 9:30 AM  
**Analyst:** AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	7/2/25	10:40 AM	EB	SM 9222G
Total coliforms:	0/100mls	2/100mls	7/2/25	10:40 AM	EB	SM 9222B
Standard plate count:	0/ml	200/ml	7/1/25	5:37 PM	SL	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.8 SU	7.2 - 7.8 SU	7/1/25	2:10 PM	SH	DPD
Chlorine:	2.0 mg/l	1.0 - 5.0 mg/l	7/1/25	2:10 PM	SH	DPD
Turbidity:	1 NTU	1 - 2 NTU	7/1/25	2:10 PM	SH	Visual

**Sample comments**

( When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor