



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

E-2

Lab# 292

Customer

Facility Name: Springhill Suites Latrobe

Address: 115 Arnold Palmer Dr.
Latrobe, PA 15650

Matrix: Recreational Water

Source Type: Pool

Sample Collection

Date: 11/24/25

Time: 11:47 AM

Method: Grab

Sample Final Analysis

Date: 11/27/25

Time: 11:00 AM

Analyst: AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	11/25/25	10:30 AM	AS	SM 9222G
Total coliforms:	0/100mls	2/100mls	11/25/25	10:30 AM	AS	SM 9222B
Standard plate count:	80/ml	200/ml	11/24/25	4:45 PM	AS	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.4 SU	7.2 - 7.8 SU	11/24/25	11:47 AM	JC	DPD
Chlorine:	3.0 mg/l	1.0 - 5.0 mg/l	11/24/25	11:47 AM	JC	DPD
Turbidity:	1 NTU	1 - 2 NTU	11/24/25	11:47 AM	JC	Visual

Sample comments

Andre Smith, Lead Supervisor

(When exceeding reporting limit pool or spa is unfit)