



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

E-2

Lab# 223

Customer

Facility Name: *McKeesport High School*

Address: *1960 Eden Park Blvd.*
McKeesport, PA 15132

Matrix: *Recreational Water*

Source Type: *Pool Deep*

Sample Collection

Date: *11/24/25*

Time: *3:22 PM*

Method: *Grab*

Sample Final Analysis

Date: *11/27/25*

Time: *11:00 AM*

Analyst: *AS*

Accredited Analysis	Results	Reporting limit	Incubation	Date/Time	Analyst	Method
Escherichia Coli:	Absent	Absent	11/25/25	10:30 AM	AS	SM 9222G
Total coliforms:	0/100mls	2/100mls	11/25/25	10:30 AM	AS	SM 9222B
Standard plate count:	0/ml	200/ml	11/24/25	4:45 PM	AS	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	8.0 SU	7.2 - 7.8 SU	11/24/25	3:22 PM	JC	DPD
Chlorine:	1.0 mg/l	1.0 - 5.0 mg/l	11/24/25	3:22 PM	JC	DPD
Turbidity:	1 NTU	1 - 2 NTU	11/24/25	3:22 PM	JC	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor