



**Dream Pools and Spas**  
**1105 Washington Blvd**  
**Pittsburgh, Pennsylvania 15206**  
**(412) 661- 7665**  
**Laboratory Analysis Report**

Lab ID No. 02-04041

**APM**

**Lab# 407**

C1

**Customer**      *American Pools Management*  
*3261 Babcock Blvd.*  
*Pittsburgh, PA 15237*

*Facility Name:*      *Morrow Park*  
  
*Address:*            *5250 Liberty Ave*  
                              *Pittsburgh, PA 15224*

*Matrix:*                *Recreational Water*  
  
*Source Type:*        *Spa*

**Sample Collection**

*Date:*                    *12/16/25*  
*Time:*                  *11:18 AM*  
*Method:*               *Grab*

**Sample Final Analysis**

*Date:*                    *12/19/25*  
*Time:*                  *10:00 AM*  
*Analyst:*                *AS*

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	12/17/25	9:30 AM	AS	SM 9222G

Total coliforms:	0/100mls	2/100mls	12/17/25	9:30 AM	AS	SM 9222B
Standard plate count:	0/ml	200/ml	12/16/25	3:15 PM	AS	SM 9215B

Additional Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Fecal Streptococcus	0/100mls	2/100mls	12/17/25	11:15 AM	AS	SM 9230C

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.6 SU	7.2 - 7.8 SU	12/16/25	11:18 AM	GR	DPD
Chlorine:	2.0 mg/l	1.0 - 5.0 mg/l	12/16/25	11:18 AM	GR	DPD
Turbidity:	1 NTU	1 - 2 NTU	12/16/25	11:18 AM	GR	Visual

**Sample comments**

Andre Smith, Lead Supervisor

( When exceeding reporting limit pool or spa is unfit)