



**Dream Pools and Spas**  
**1105 Washington Blvd**  
**Pittsburgh, Pennsylvania 15206**  
**(412) 661-7665**  
**Laboratory Analysis Report**

Lab ID No. 02-04041

N-13

Lab# 433

**Customer**

Facility Name: Atria Senior Living  
Address: 8870 Duncan Ave.  
Pittsburgh, PA 15237  
Matrix: Recreational Water  
Source Type: Pool

**Sample Collection**

Date: 6/16/25  
Time: 12:16 PM  
Method: Grab

**Sample Final Analysis**

Date: 6/19/25  
Time: 10:00 AM  
Analyst: AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time	Analyst	Method	
Escherichia Coli:	Absent	Absent	6/17/25	10:40 AM	EB	SM 9222G
Total coliforms:	0/100mls	2/100mls	6/17/25	10:40 AM	EB	SM 9222B
Standard plate count:	0/ml	200/ml	6/16/25	5:45 PM	EB	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time	Analyst	Method	
pH:	7.6 SU	7.2 - 7.8 SU	6/16/25	12:16 PM	MM	DPD
Chlorine:	3.0 mg/l	1.0 - 5.0 mg/l	6/16/25	12:16 PM	MM	DPD
Turbidity:	1 NTU	1 - 2 NTU	6/16/25	12:16 PM	MM	Visual

**Sample comments**

( When exceeding reporting limit pool or spa is unfit)

A handwritten signature in black ink that reads "Andre Smith".

Andre Smith, Lead Supervisor



**Dream Pools and Spas**  
**1105 Washington Blvd**  
**Pittsburgh, Pennsylvania 15206**  
**(412) 661-7665**  
**Laboratory Analysis Report**

Lab ID No. 02-04041

N-13

Lab# 433

**Customer**

Facility Name: Atria Senior Living  
Address: 8870 Duncan Ave.  
Pittsburgh, PA 15237  
Matrix: Recreational Water  
Source Type: Pool

**Sample Collection**

Date: 6/16/25  
Time: 12:16 PM  
Method: Grab

**Sample Final Analysis**

Date: 6/19/25  
Time: 10:00 AM  
Analyst: AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time	Analyst	Method	
Escherichia Coli:	Absent	Absent	6/17/25	10:40 AM	EB	SM 9222G
Total coliforms:	0/100mls	2/100mls	6/17/25	10:40 AM	EB	SM 9222B
Standard plate count:	0/ml	200/ml	6/16/25	5:45 PM	EB	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time	Analyst	Method	
pH:	7.6 SU	7.2 - 7.8 SU	6/16/25	12:16 PM	MM	DPD
Chlorine:	3.0 mg/l	1.0 - 5.0 mg/l	6/16/25	12:16 PM	MM	DPD
Turbidity:	1 NTU	1 - 2 NTU	6/16/25	12:16 PM	MM	Visual

**Sample comments**

( When exceeding reporting limit pool or spa is unfit)

A handwritten signature in black ink that reads "Andre Smith".

Andre Smith, Lead Supervisor