Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

E - 11

Lab#   272

Customer

Facility Name:	*Seven Springs Resort*
Address:	*777 Waterwheel Dr. Champion, PA 15622*
Matrix:	*Recreational Water*
Source Type:	*Pool*

Sample Collection

Date:	*8/11/25*
Time:	11:27 AM
Seven Springs Method:	*Grab*

Sample Final Analysis

Date:	*8/14/25*
Time:	*9:00 AM*
Analyst:	*AS*

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	8/12/25	10:00 AM	AH	SM 9222G
Total coliforms:	0/100mls	2/100mls	8/12/25	10:00 AM	AH	SM 9222B
Standard plate count:	0/ml	200/ml	8/11/25	5:20 PM	SL	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.2 SU	7.2 - 7.8 SU	8/11/25	11:27 AM	JC	DPD
Chlorine:	3.0 mg/l	1.0 - 5.0 mg/l	8/11/25	11:27 AM	JC	DPD
Turbidity:	1 NTU	1 - 2 NTU	8/11/25	11:27 AM	JC	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith

Andre Smith, Lead Supervisor

Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

E - 11

Lab# 272

Customer

Facility Name:	*Seven Springs Resort*			
Address:	*777 Waterwheel Dr.*			
	Champion, PA 15622			
Matrix:	*Recreational Water*			
Source Type:	*Pool*			

Sample Collection

Date:	*8/11/25*
Time:	11:27 AM
Seven Springs Method:	*Grab*

Sample Final Analysis

Date:	*8/14/25*
Time:	*9:00 AM*
Analyst:	*AS*

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	8/12/25	10:00 AM	AH	SM 9222G
Total coliforms:	0/100mls	2/100mls	8/12/25	10:00 AM	AH	SM 9222B
Standard plate count:	0/ml	200/ml	8/11/25	5:20 PM	SL	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.2 SU	7.2 - 7.8 SU	8/11/25	11:27 AM	JC	DPD
Chlorine:	3.0 mg/l	1.0 - 5.0 mg/l	8/11/25	11:27 AM	JC	DPD
Turbidity:	1 NTU	1 - 2 NTU	8/11/25	11:27 AM	JC	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

_____
Andre Smith, Lead Supervisor