



Dream Pools And Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

APM 1

Lab# 2121

Customer *American Pools Management*
3261 Babcock Blvd.
Pittsburgh, PA 15237

Sample Collection

Facility Name: *Club at North Hills*

Address: *700 Lincoln Club Drive*
Pittsburgh, PA 15237

Date: 6/16/25
Time: 1:07 PM
Method: *Grab*

Sample Final Analysis

Matrix: *Recreational Water*

Source Type: *Pool*

Date: 6/19/25
Time: 10:00 AM
Analyst: AS

Accredited Analysis	Results	Reporting limit	Incubation	Date/Time	Analyst	Method
Escherichia Coli:	Absent	Absent	6/17/25	10:40 AM	AH	SM 9222G
Total coliforms:	0/100mls	2/100mls	6/17/25	10:40 AM	AH	SM 9222B
Standard plate count:	0/ml	200/ml	6/16/25	5:45 PM	EB	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time	Analyst	Method	
pH:	7.6 SU	7.2 - 7.8 SU	6/16/25	1:07 PM	MM	DPD
Chlorine:	3.0 mg/l	1.0 - 5.0 mg/l	6/16/25	1:07 PM	MM	DPD
Turbidity:	1 NTU	1 - 2 NTU	6/16/25	1:07 PM	MM	Visual

Sample comments

Andre Smith

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor



Dream Pools And Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

APM 1

Lab# 2121

Customer *American Pools Management*
3261 Babcock Blvd.
Pittsburgh, PA 15237

Sample Collection

Facility Name: *Club at North Hills* *Date:* *6/16/25*
Address: *700 Lincoln Club Drive* *Time:* *1:07 PM*
Pittsburgh, PA 15237 *Method:* *Grab*

Sample Final Analysis

Matrix: *Recreational Water* *Date:* *6/19/25*
Source Type: *Pool* *Time:* *10:00 AM*
Analyst: *AS*

Accredited Analysis	Results	Reporting limit	Incubation	Date/Time	Analyst	Method
Escherichia Coli:	Absent	Absent	6/17/25	10:40 AM	AH	SM 9222G
Total coliforms:	0/100mls	2/100mls	6/17/25	10:40 AM	AH	SM 9222B
Standard plate count:	0/ml	200/ml	6/16/25	5:45 PM	EB	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time	Analyst	Method
pH:	7.6 SU	7.2 - 7.8 SU	6/16/25 1:07 PM	MM	DPD
Chlorine:	3.0 mg/l	1.0 - 5.0 mg/l	6/16/25 1:07 PM	MM	DPD
Turbidity:	1 NTU	1 - 2 NTU	6/16/25 1:07 PM	MM	Visual

Sample comments

Andre Smith

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor