Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

N-10

Lab# 2376

Customer		*Sample Collection*	
Facility Name:	*Oakmont C.C.*	*Date:*	*8/5/25*
		Time:	2:25 PM
Address:	*1233 Hulton Road*	*Method:*	*Grab*
	Oakmont, PA 15139		
		Sample Final Analysis	
Matrix:	*Recreational Water*	*Date:*	*8/8/25*
		Time:	*8:30 AM*
Source Type:	*Deep End*	*Analyst:*	*AS*

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	8/6/25	2:00 PM	AH	SM 9222G
Total coliforms:	0/100mls	2/100mls	8/6/25	2:00 PM	AH	SM 9222B
Standard plate count:	0/ml	200/ml	8/5/25	5:40 PM	AS	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.6 SU	7.2 - 7.8 SU	8/5/25	2:25 PM	BH	DPD
Chlorine:	2.0 mg/l	1.0 - 5.0 mg/l	8/5/25	2:25 PM	BH	DPD
Turbidity:	1 NTU	1 - 2 NTU	8/5/25	2:25 PM	BH	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith

Andre Smith, Lead Supervisor

Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

N-10

Lab# **2376**

Customer		*Sample Collection*	
Facility Name:	*Oakmont C.C.*	*Date:*	*8/5/25*
		Time:	2:25 PM
Address:	*1233 Hulton Road*	*Method:*	*Grab*
	Oakmont, PA 15139		
		Sample Final Analysis	
Matrix:	*Recreational Water*	*Date:*	*8/8/25*
		Time:	*8:30 AM*
Source Type:	*Deep End*	*Analyst:*	*AS*

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	8/6/25	2:00 PM	AH	SM 9222G
Total coliforms:	0/100mls	2/100mls	8/6/25	2:00 PM	AH	SM 9222B
Standard plate count:	0/ml	200/ml	8/5/25	5:40 PM	AS	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.6 SU	7.2 - 7.8 SU	8/5/25	2:25 PM	BH	DPD
Chlorine:	2.0 mg/l	1.0 - 5.0 mg/l	8/5/25	2:25 PM	BH	DPD
Turbidity:	1 NTU	1 - 2 NTU	8/5/25	2:25 PM	BH	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith

Andre Smith, Lead Supervisor