

## Dream Pools And Spas 1105 Washington Blvd Pittsburgh, Pennsylvania 15206 (412) 661- 7665 Laboratory Analysis Report

Lab ID No. 02-04041 **APM 1** 

Lab# 2057

Customer American Pools Management

3261 Babcock Blvd. Pittsburgh, PA 15237

Facility Name: Brentwood Borough Pool

Address: Park Dr.

Pittsburgh, PA 15227

Matrix: Recreational Water

Source Type: Shallow End

Sample Collection

Date: 5/28/25 Time: 12:10 PM

Method: Grab

Sample Final Analysis

 Date:
 5/31/25

 Time:
 9:30 AM

 Analyst:
 AS

**Accredited Analysis** Reporting limit Results Incubation Date/Time Analyst Method Escherichia Coli: Absent Absent 5/29/25 10:05 AM EΒ SM 9222G Total coliforms: 0/100mls 2/100mls 5/29/25 10:05 AM EΒ SM 9222B Standard plate count: 200/ml 5/28/25 5:36 PM AΗ SM 9215B 0/ml

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method	-
pH:	7.8 SU	7.2 - 7.8 SU	5/28/25	12:10 PM	DW	DPD	
Chlorine:	0.0 mg/l	1.0 - 5.0 mg/l	5/28/25	12:10 PM	DW	DPD	
Turbidity:	1 NTU	1 - 2 NTU	5/28/25	12:10 PM	DW	Visual	

## Sample comments

( When exceeding reporting limit pool or spa is unfit)

andre Smith

Andre Smith, Lead Supervisor



## Dream Pools And Spas 1105 Washington Blvd Pittsburgh, Pennsylvania 15206 (412) 661- 7665 Laboratory Analysis Report

Lab ID No. 02-04041 **APM 1** 

Lab# 2057

Customer American Pools Management

3261 Babcock Blvd. Pittsburgh, PA 15237

Facility Name: Brentwood Borough Pool

Address: Park Dr.

Pittsburgh, PA 15227

Matrix: Recreational Water

Source Type: Shallow End

Sample Collection

Date: 5/28/25 Time: 12:10 PM

Method: Grab

Sample Final Analysis

 Date:
 5/31/25

 Time:
 9:30 AM

 Analyst:
 AS

**Accredited Analysis** Reporting limit Results Incubation Date/Time Analyst Method Escherichia Coli: Absent Absent 5/29/25 10:05 AM EΒ SM 9222G Total coliforms: 0/100mls 2/100mls 5/29/25 10:05 AM EΒ SM 9222B Standard plate count: 200/ml 5/28/25 5:36 PM AΗ SM 9215B 0/ml

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method	-
pH:	7.8 SU	7.2 - 7.8 SU	5/28/25	12:10 PM	DW	DPD	
Chlorine:	0.0 mg/l	1.0 - 5.0 mg/l	5/28/25	12:10 PM	DW	DPD	
Turbidity:	1 NTU	1 - 2 NTU	5/28/25	12:10 PM	DW	Visual	

## Sample comments

( When exceeding reporting limit pool or spa is unfit)

andre Smith

Andre Smith, Lead Supervisor