



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

S-10

Lab# 2054

Customer

Facility Name: *Bower Hill Swim Club*
Address: *1600 Bower Hill Road*
Pittsburgh, PA 15243

Matrix: *Recreational Water*
Source Type: *Wading Pool*

Sample Collection

Date: *7/28/25*
Time: *11:02 AM*
Method: *Grab*

Sample Final Analysis

Date: *7/31/25*
Time: *9:00 AM*
Analyst: *AS*

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	7/29/25	10:00 AM	AH	SM 9222G
Total coliforms:	0/100mls	2/100mls	7/29/25	10:00 AM	AH	SM 9222B
Standard plate count:	0/ml	200/ml	7/28/25	4:45 PM	EB	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.8 SU	7.2 - 7.8 SU	7/28/25	11:02 AM	CW	DPD
Chlorine:	1.0 mg/l	1.0 - 5.0 mg/l	7/28/25	11:02 AM	CW	DPD
Turbidity:	1 NTU	1 - 2 NTU	7/28/25	11:02 AM	CW	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith

Andre Smith, Lead Supervisor



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

S-10

Lab# 2054

Customer

Facility Name: Bower Hill Swim Club
Address: 1600 Bower Hill Road
Pittsburgh, PA 15243

Matrix: Recreational Water
Source Type: Wading Pool

Sample Collection

Date: 7/28/25
Time: 11:02 AM
Method: Grab

Sample Final Analysis

Date: 7/31/25
Time: 9:00 AM
Analyst: AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	7/29/25	10:00 AM	AH	SM 9222G
Total coliforms:	0/100mls	2/100mls	7/29/25	10:00 AM	AH	SM 9222B
Standard plate count:	0/ml	200/ml	7/28/25	4:45 PM	EB	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.8 SU	7.2 - 7.8 SU	7/28/25	11:02 AM	CW	DPD
Chlorine:	1.0 mg/l	1.0 - 5.0 mg/l	7/28/25	11:02 AM	CW	DPD
Turbidity:	1 NTU	1 - 2 NTU	7/28/25	11:02 AM	CW	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith

Andre Smith, Lead Supervisor