



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

N-2

Lab# 464

Customer

Facility Name: *Big Blue Swim School*

Address: *20412 US Rt19*
Cranberry, PA 16066

Matrix: *Recreational Water*

Source Type: *Pool*

Sample Collection

Date: *9/3/25*

Time: *11:30 AM*

Method: *Grab*

Sample Final Analysis

Date: *9/6/25*

Time: *2:00 PM*

Analyst: *AS*

| Accredited Analysis | Results | Reporting limit | Incubation Date/Time | | Analyst | Method |
|-----------------------|----------|-----------------|----------------------|---------|---------|----------|
| Escherichia Coli: | Absent | Absent | 9/4/25 | 9:15 AM | JC | SM 9222G |
| Total coliforms: | 0/100mls | 2/100mls | 9/4/25 | 9:15 AM | JC | SM 9222B |
| Standard plate count: | 0/ml | 200/ml | 9/3/25 | 3:10 PM | SL | SM 9215B |

| Field Analysis | Results | Reporting limit | Date/Time | | Analyst | Method |
|----------------|----------|-----------------|-----------|----------|---------|--------|
| pH: | 7.4 SU | 7.2 - 7.8 SU | 9/3/25 | 11:30 AM | VH | DPD |
| Chlorine: | 3.0 mg/l | 1.0 - 5.0 mg/l | 9/3/25 | 11:30 AM | VH | DPD |
| Turbidity: | 1 NTU | 1 - 2 NTU | 9/3/25 | 11:30 AM | VH | Visual |

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor